



水務署

Water Supplies Department

香港灣仔告士打道七號入境事務大樓
Immigration Tower, 7 Gloucester Road, Hong Kong

電子郵遞
e-mail wsdinfo@wsd.gov.hk

電話
Telephone 2829 4367

圖文傳真
Facsimile 2824 0578

檔號
Reference (4) in WSD 3321/16 Pt.1 T/J(281)

5 April 2016

Delabie Ltd.
21/F, On Hing Building,
1 On Hing Terrace,
Central, Hong Kong

(Attn.:Mr. Sebastien SPRIET)

Dear Sir,

Approval of "DELABIE" Manually Operated Blending Valves

Your letters ref. HK2439 dated 12 February 2016 and 16 March 2016 refer.

It is noted that the fittings described below have been accepted by the United Kingdom Water Regulations Advisory Scheme (WRAS) to have complied with the requirements of the United Kingdom Water Supply (Water Fittings) Regulations / Scottish Water Byelaws when correctly installed.

Name of Manufacturer:	Delabie SCS
Country of Origin:	France
Brand:	Delabie
Details of Fittings:	Range of wall mounted, manually operated, exposed blending valves (chromium plated brass bodies) incorporating a ceramic cartridge headwork controlling both flow and temperature with single lever operating member. Supplied with $\frac{3}{4}$ " x $\frac{1}{2}$ " offset union adaptors that incorporate spherical valves. The inlets incorporate plastic flow restrictors. Models 2439 & 2439EP also incorporate plastic strainers at the inlet. Models 2739 &

2739EP incorporate a single check valve cartridge (suitable for backflow protection up to Fluid Category 2). Maximum working pressure 5.0 bar. Maximum operating temperature 60°C.

Models: 2439, 2439EP, 2739 & 2739EP

Size: ¾" x ½" offset union inlets x ½" BSP male outlet

Marking: 'Delabie' on operating member

WRAS Approval Number: 1511019

Installation Requirements: R001, R010, R040

Expiry Date: 30 November 2020

In view of the acceptance by WRAS, this Authority has no objection to the use of the said fittings in fresh water supply plumbing systems subject to full adherence to Waterworks installation requirements. In particular, you are required to draw your customers' attention to the following installation requirements –

“Installation shall comply with the ‘Installation Requirements & Notes’ of the WRAS’s approval letter concerned.” AND

“The cold water supply to the fittings shall be drawn from the same source that supplies the hot water apparatus so as to provide a balanced pressure and to obviate the risk of scalding in the event of a restriction or failure in the water supply.”


A condition of this acceptance is that the fittings to be installed should be replicas of the samples certified by WRAS and no modification should be made to the fittings. This acceptance may be withdrawn at any time if the standard of the fittings installed fails to meet that of the approved samples or if the fittings are found to be unsuitable for use in fresh water supply plumbing systems.

This acceptance is only applicable to the main body of the fittings, unless other specified.

For the use of the fittings in any project, the Acceptance Reference Number at the bottom of this letter must be quoted as a means of identification of acceptance of the fittings by this Authority.

Should you have any enquiries, please contact our Engineer Ms. K L FOK at tel. no. 2829 5657.

Yours faithfully,



(K K LI)
for Water Authority

c.c. WSD 3321/1/82] - without catalogue
 E/CS(TS)1] - with soft copy only