



水務署

Water Supplies Department

香港灣仔告士打道七號入境事務大樓
Immigration Tower, 7 Gloucester Road, Hong Kong

電子郵件
e-mail wsdinfo@wsd.gov.hk

電話
Telephone 2829 4367

圖文傳真
Facsimile 2824 0578

檔號
Reference (4) in WSD 3321/16 Pt.1 T/J(927)

6 July 2016

Delabie Ltd
21/F, On Hing Building,
1 On Hing Terrace,
Central, Hong Kong

(Attn.: Mr Sebastien Spriet)

Dear Sir,

Approval of "DELABIE" Combination Tap Assemblies

Your letters ref. HK490 dated 9 June 2016 and 21 June 2016 refer.

It is noted that the fittings described below have been accepted by the United Kingdom Water Regulations Advisory Scheme (WRAS) to have complied with the requirements of the United Kingdom Water Supply (Water Fittings) Regulations / Scottish Water Byelaws when correctly installed.

Name of Manufacturer: Delabie SCS

Country of Origin: France

Brand: Delabie

Details of Fitting: Range of deck mounted, single hole, single outlet (fixed) electronically controlled tap assemblies (chromium plated brass). The flow is controlled via a solenoid valve activated by an infra-red sensor. The 490006 & 49200615 models incorporate a single lever temperature control. The spout outlet incorporates a plastic aerator. The inlet hoses of the 490006 & 49200615 models incorporate single check valve cartridges (suitable for backflow prevention against

fluid category 2). All inlet hoses are supplied with plastic strainers and isolation valves. The 49200615 & 44200615 models are supplied with a 3/8"x1/2" BSP (M) adaptor. Maximum working pressure 5.0 bar. Maximum operating temperature 60°C.

Model: 440006, 490006, 440001HK, 44200615 & 49200615

Size: Stainless Steel braided hose PEX lined with 3/8" BSP captive nut

Marking: Delabie on the end of the spout

WRAS Approval Number: 1603070

Installation Requirements: R001, R006, R009

Expiry Date: 31 March 2021

In view of the acceptance by WRAS, this Authority has no objection to the use of the said fittings in fresh water supply plumbing systems subject to full adherence to Waterworks installation requirements. In particular, you are required to draw your customers' attention to the following installation requirements –

“Installation shall comply with the ‘Installation Requirements & Notes’ of the WRAS’s approval letter concerned.”

“The cold water supply to the fittings shall be drawn from the same source that supplies the hot water apparatus so as to provide a balanced pressure and to obviate the risk of scalding in the event of a restriction or failure in the water supply.”

“A stop cock or gate valve must be installed at the upstream of the fittings for manual isolation of water supply.” AND

“The main voltage operated sensor valves should comply with the electricity safety regulation for applications in bathroom, toilet etc.”

A condition of this acceptance is that the fittings to be installed should be replicas of the samples certified by WRAS and no modification should be made to the fittings. This acceptance may be withdrawn at any time if the standard of the fittings installed fails to meet that of the approved samples or if the fittings are found to be unsuitable for use in fresh water supply plumbing systems.

This acceptance is only applicable to the main body of the fittings, unless other specified.

For the use of the fittings in any project, the Acceptance Reference Number at the bottom of this letter must be quoted as a means of identification of acceptance of the fittings by this Authority.

Should you have any enquiries, please contact our Engineer Mr Terry KUNG at tel. no. 2294 2656.

Yours faithfully,



(LAM Ching Man)
for Water Authority

c.c. WSD 3321/1/82] - without catalogue
 ME/CS(MC)] - with soft copy only